

Village of Lakewood
2024 Farmers' and Artisans' Market
Proposed

Dates: Every Thursday, June 20th – September 5th
(Including Thursday July 4th)

Time: 10 am – 2PM

Location: Chautauqua Ave, between Summit and Alta Way
(With road closure of Chautauqua Ave)

Fees: \$10/week or \$100/entire season

Market Manager: Taryn Wilson Wheatley

LAKWOOD FIRE DEPARTMENT
FIRE STATION NEEDS AND STRUCTURAL DEFICIENCIES
September, 2023

FIXTURES AND EQUIPMENT THAT WILL SOON NEED TO BE REPLACED:

- 1) 6 Overhead garage doors, (window seal compromise; some panels filled with water, hardware loose and missing) 5-14' doors, 1-12' door, approx. \$7K apiece.
- 2) 5 Overhead garage door operators. (28 years old. A371 bay operator is new-2023)
- 3) Aluminum trim around all garage doors. Rusted through at the bottom.
- 4) 1 100Kw standby generator that powers the fire station and DPW garage. (\$100,000+) (28 years old, has a 1982 Ford engine)
- 5) Overhead torpedo heaters are 28 years old.
- 6) **Exhaust removal system brought over from the 20 W. Summit St. station and no longer connects to trucks. Recoil mechanisms do not work. New Plymovent system is (\$100,000+) Grants available.
- 7) Countertop in radio room is missing sections of Formica laminate top and fronts.
- 8) Desks and accompanying furniture is 28 years old and is showing age.
- 9) Carpeting is also 28 years old-original and is showing wear.
- 10) Apparatus bays need to be painted.

OPERATIONAL DIFFICULTIES:

- 1) Apparatus bays are full. When building was built, we only had one ambulance and a county fly car was not stationed here. Vehicles continue to get bigger.

- 2) **Upstairs weight/exercise room/ Computer server room, are not heated or air conditioned. Hard for people to work out in those conditions. Computer equipment should be climate controlled.
- 3) Upstairs storage areas (Quartermaster/computer room/file room) have reached capacity. No further expansion possible upstairs because of lack of floor support.)
- 4) Training room is small for some drills/classes.
- 5) Bunk room was replaced by a needed EMS Department office, so no real place for county medic or on duty members to rest/sleep. We need to think of this in terms of someday being a career station with personnel on duty 24 hours.
- 6) Gear lockers are all assigned and no additional ones are available for new members.
- 7) **With forthcoming information on carcinogens affecting firefighters, a locker room area that houses firefighting gear and shower facilities separate from working spaces inside the station should be established.
- 8) Museum is full and is very hard to walk through because of the number of artifacts.
- 9) 3 Furnaces (2-main building; 1-museum) were replaced in 2019 and should be sufficient.)
- 10) Solar panels on the roof of the building are very old and should be removed or replaced and condition of the roof re-assessed.

SUGGESTIONS FOR RENOVATION OF EXISTING BUILDING:

- 1) Add 40 feet, (1 or 2 bays) on the East side of the station toward the DPW garage facing Packard Blvd. (OR) Facing the DPW garage, 4 additional overhead doors facing East to house 2 ambulances, county fly car and M371 pickup truck, and EMS storage or possibly a locker room/gear storage area.

****= Health and Safety issue**

Fire Guys Bounce House & Party Rentals

\$750 Bundle

- 2- 32' obstacle course
- 1 Basic Bounce House

\$1000 Bundle

- 22' slide with slip and slide
- 1 Carnival size house house
- 1 dunk tank

\$1500 Bundle

- 22' slide with slip and slide
- 1 Carnival size house house
- 1 dunk tank
- 2- 32' foot obstacle course

** The Company came back and stated that they would be willing to do the \$1500 bundle for \$1000